

NUBBIN SLOUGH

W912EP-04-B-0001 (A0003)

CONTRACTOR QUESTIONS

1. In the plans and specs, we have found that the Force Main material can be either HDPE or DIP in the specs, however the plans call it out as HDPE.

Answer: See Amendment No 0003.

2. Due to the larger internal diameter of DIP, a 42" diameter DIP Pipe can be substituted for the 48" PE. Would the Corps consider this smaller diameter DIP line?

Answer: No – See Section 02532