

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

QUESTIONS AND ANSWERS

Q.1 Reference Appendix A, Sheet 14 of 75, (Drawing Package), "S13 M-4 Sensor Location (1)"; Leader Text states "AVOID BOLT INTERFERENCE SEE NOTE 4 THIS SHEET." The notes stop at #3. Please provide missing Note 4.

A.1 Add Note 4 to drawing S-13 M-4:

4. ONCE METAL IS ENCOUNTERED, DRILL THROUGH ANGLE WITH DRILL BIT FOR METAL. IF CONCRETE IS NOT PRESENT AFTER 0.5" OF DRILLING THROUGH METAL, ADJUST PILOT HOLE 2.0" TOWARD NEXT PILOT HOLE LOCATION. FILL ABANDONED HOLE WITH NON-SHRINK GROUT.

Q.2 CADD Files:

What version/revision of MicroStation is the Using Agency currently working with?

A.2 Current MicroStation version is MicroStation J (07.01.00.62 Windows x86).

Q.3 Contract Award Date:

How soon after Bid submittals will there be a Contract Award?

A.3 Approximately two months.

Q.4 Delivery Order Awards:

When will Delivery Orders be issued?

Will they be awarded annually, and if so, during what month?

A.4 The first delivery order will be issued upon completion of post award administrative functions as stated throughout the solicitation. The issuance of subsequent orders will be based on material procurement lead time and work progress on previous order.