

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES	
				J	1	2
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 23-Dec-2002	4. REQUISITION/PURCHASE REQ. NO. W32CS520284764		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, JACKSONVILLE PRUDENTIAL OFFICE BLDG 701 SAN MARCO BLVD CESAJ-CT JACKSONVILLE FL 32207-8175		CODE DACW17	7. ADMINISTERED BY (If other than item 6) CO GULF COAST AREA OFFICE CONOPS-GULF COAST OFFICE PO BOX 19247 TAMPA FL 33686-9247		CODE DACW17	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. DACW17-03-B-0003	
				X	9B. DATED (SEE ITEM 11) 29-Nov-2002	
					10A. MOD. OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) DEWATERING BULKHEADS REPAIRS, C&F PROJECT FOR FLOOD CONTROL AND OTHER PURPOSES, HENDRY COUNTY, FLORIDA  The Purpose of this Amendment is to address questions from the Site Conference 6 Dec 2002. (See page 2 for DESCRIPTIVE CHANGES)  BID OPENING REMAINS 7 JAN 2003 AT 2:00 PM.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		24-Dec-2002	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE  
SUMMARY OF CHANGES

**1. SPECIFICATIONS:** NO CHANGES to the Specifications.

**2. DRAWINGS:** D. O. File No. 400-38,296 dated April 2002 in 11 Sheets + Cover. NO CHANGES to the Drawings other than the DESCRIPTIVE DRAWING CHANGES indicated below.

**DESCRIPTIVE DRAWING CHANGES :** The following are descriptive changes to the drawings. Drawings should be adequately marked to indicate that they have been changed.

**CHANGE** the Solicitation “IFB No. DACW17-02-B-0013” on all 11 Sheets + Cover to “IFB No. DACW17-03-B-0003”.

DRAWING NO. S-3; ZONE F-G-H/3: **REVISE NOTE 1** to read as follows: “20 bulkheads of S-79 Spillway shall be sand blasted and cleaned of loose material before making repairs and painting.”

DRAWING NO. S-3; ZONE F-G-H/1: **ADD** the following new NOTE: “16. Pickup beams of S-79 Spillway and S-354 are not part of this solicitation.”

DRAWING NO. S-3; ZONE F-G-H/1: **ADD** the following new NOTE: “17. Provide ¾” diameter hole in the stiffener plate at the junction of each stiffener plate with the web and flange of top W33x130 beam. Provide an additional drain hole in the middle between two existing holes at locations of severe corrosion in beam web. New hole size shall be the same size as the existing holes.”

DRAWING NO. S-3; ZONE F-G-H/1: **ADD** the following new NOTE: “18. Contractor shall not remove the stamped or imprinted bulkhead identifying numbers or markings at both ends of the bulkheads for S-79 Spillway and S-354. If they are missing, Contractor shall imprint the identifying numbers or markings 1 and ½” high at both ends of the bulkheads before sandblasting.”

DRAWING NO. S-3; ZONE D-E/5: In NOTE under “REPAIR DETAIL NO. 2”, **DELETE** the last sentence that reads as follows: “Do not clip corners of the new plates.”

*(End of Summary of Changes)*